

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. CHC/083

Date : 13/08/2026

It is certified that an inspection team headed by CHC Babina
Kamhaijalal Raghavanshi from _____ inspected the
Carmel Convent School, Behind Power House, Hansari, Jhansi on
_____ and found that the **Carmel Convent School** has safe drinking
water facilities for the students and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building & the campus as
per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 3 years -

To
The Principal
Carmel Convent School
Behind Power House
Hansari, Jhansi

Signature with Seal : _____

Name : Kamhaijalal Raghavanshi

Designation : H.E.O

H.E.O
Community Health Centre
Babina

Sharlet
Principal,
Carmel Convent School,
Hasari, Jhansi (U.P.)

Sh. D. B. S.
Manager
Carmel Convent School
Hasari-Jhansi

Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Babina, Jhansi

Report Number- A/26-27/012380

Date- 10-04-2026

Page No.- 408(2)

Customer Details

Office Name and Address The Principal, Carmel Convent School Hansari, Jhansi (U.P.)

Basic details of Sample

Distrcit	Jhansi	Block	-
Gram Panchayat	-	Village	Carmel Convent School Hansari,
Habitation	-	Location	Jhansi (U.P.)
Source	Borewell	Sample Number	102
Quantity of sample	2 Lit	Date of sample collection	10.04.2026
Sample receiving date	10-04-2026	Name of sample collector	Principal
Name of Sample depositor ,	WILLIAM	Date of Initiation of Test.	22.04.2026
Date of Completion of Test	22.04.2026		

Technical Data of Analysis

S.No.	TESTED PARAMETERS	OBSERVED VALUES	SPECIFIED VALUES AS Per BIS 10500: 2012		TEST METHOD
			Acceptable Limit	Permissible Limit in the absence of Alternate source	
1	pH.	5.80	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2023
2	Turbidity (NTU)	4.05	1.0	5.0	IS 3025 (Part 10): 2023
3	Chloride (mg/l)	234	250	1000	IS 3025 (Part 32): 2019
4	Total Hardness (mg/l)	143.0	200	600	IS 3025 (Part 21): 2019
5	Calcium as Ca (mg/l)	80.00	75	200	IS 3025 (Part 40): 2023
6	Alkalinity (mg/l)	152.00	200	600	IS 3025 (Part 23): 2023
7	Magnesium as Mg (mg/l)	8.77	30	100	IS 3025 (Part 46): 2023
8	Suphate (mg/l)	105.80	200	400	IS 3025 (Part 24 Sec 1): 2022
9	TDS (mg/l)	220	500	2000	IS 3025 (Part 16): 2023
10	Iron (mg/l)	1.77	1	1	IS 3025 (Part 53): 2019
11	Fluoride (mg/l)	1.600	1.0	1.5	IS 3025 (Part 60): 2022

NOTE:

1. This certificate is only applicable for the above tested parameters.
2. Parameters above permissible limit are bold.
3. This certificate refers only to the particular sample (s) submitted for testing.
4. This certificate shall not be reproduce, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of
5. The test result reported in the certificate are valid at the time of an under the stated conditions of measurements.
6. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports other wise specied.

End of the Report

Issued by
(Yashvendra singh)
Technical Manager

Sharlet
Principal,
Carmel Convent School,
Hasari, Jhansi (U.P.)

Yashvendra Singh
Manager
Carmel Convent School
Hasari-Jhansi